

CA20N
EP
-2017

Ontario Hydro Lakeview Generating Station Selected Design Specifications

| | Units 1 & 2 | Units 3 & 4 | Units 5 & 6 | Units 7 & 8 |
|--|---|---|--|---|
| Electric Power Output | | | | |
| Installed Capacity | 300,000 kW/unit | 300,000 kW/unit | 300,000 kW/unit | 300,000 kW/unit |
| Generation Voltage: (volts) | 16,000 | 18,000 | 18,000 | 18,000 |
| Transmission Voltage: (volts) | 230,000 | 230,000 | 230,000 | 230,000 |
| Steam Generator | | | | |
| Type: | natural circulation radiant boiler | controlled circulation radiant boiler | natural circulation radiant boiler | natural circulation radiant boiler |
| Design Pressure (psig) | 2,750 | 2,700 | 2,750 | 2,750 |
| Design Steam Output (lb. per hour per unit) | 2,000,000 | 2,000,000 | 2,000,000 | 2,000,000 |
| Secondary Superheater Outlet Pressure (psig) | 2,450 | 2,450 | 2,450 | 2,450 |
| Secondary Superheater Outlet Temp. (°F) | 1,000 | 1,000 | 1,000 | 1,000 |
| Coal Pulverizers (No. per Unit) | 6 | 5 | 6 | 6 |
| Coal Burners (No. Per Unit) | 24 | 40 | 18 | 18 |
| Water Temperature at Economizer inlet (°F) | 465 | 469 | 465 | 465 |
| Air Temp. at Preheater Outlet (°F) | 504 | 524 | 496 | 496 |
| Gas Temp. at Air Heater Outlet (°F) | 260 | 245 | 244 | 244 |
| Reheat Steam Temp. (°F) | 1,000 | 1,000 | 1,000 | 1,000 |
| Reheat Steam Temp. Control | Gas Recirculation fans (two per unit) | Burners tilt up and down | Gas recirculation fan - 1 per unit | Gas recirculation fan - 1 per unit |
| Furnace Observation at Control Room | Closed circuit TV - 3 cameras | Closed circuit TV - 2 cameras | Closed Circuit TV - 3 cameras | Closed circuit TV - 3 cameras |
| Water Level Observation at Control Room | Steam drum gauge glass plus two reflecting mirrors | Steam drum gauge glass plus two reflecting mirrors | Steam drum gauge glass plus two reflecting mirrors | Steam drum gauge glass plus two reflecting mirrors |
| Steam Generator Controls | | | | |
| | Pneumatic - supplied by Bailey Meter Co. | Electrical - Hagen Controls | Electrical - Bailey Meter Co. | As 5 & 6 |
| Turbines | | | | |
| Type | cross-compound, reheat, impulse reaction, single flow HP, 2 double flow IP, 2 dbl. fl. LP | tandem-compound, reheat, impulse reaction, single flow HP, single flow IP, 2 double flow LP | Same as Units 3 & 4 | tandem-compound, reheat, impulse reaction, single flow HP, single flow IP, double flow LP |
| Steam Pressure at Throttle (psig) | 2,350 | 2,350 | 2,350 | 2,350 |
| Steam Temp. at Throttle (°F) | 1,000 | 1,000 | 1,000 | 1,000 |
| Back Pressure (in Hg Absolute) | 1.0 | 1.0 | 1.0 | 1.0 |
| Number of Extraction Points | 7 | 7 | 7 | 7 |
| Pounds of Steam per Kilowatt hour Gross | 6.36 | 6.27 | 6.22 | 6.31 |
| Turbine Heat Rate at Full Load (BTU per kWh) | 7,612 | 7,613.3 | 7,627.1 | 7,546 |
| Shaft Speed (rpm) | 3,600/1,800 | 3,600 | 3,600 | 1,800 |
| Generators | | | | |
| Cooling | Rotors hydrogen cooled at 30 psig normal pressure. Conventionally cooled stator | Rotors hydrogen cooled at 30 psig normal pressure. Stators water cooled | Same as Units 3 & 4 | Same as Units 3 & 4 |
| Rating: | two 150 MW generators per unit at 0.85 power factor | one 300 MW generator per unit at 0.85 power factor | Same as Units 3 & 4 | Same as Units 3 & 4 |
| Exciters (per Unit) | Two systems. Main exciters separately driven, 1,900 amps at 415 V. D. C. Output | One exciter 3,850 amps at 480 V. D. C. - separately driven | One exciter 3,780 amps at 470 V. D. C. - separately driven | One exciter separately driven 3,200 amps at 375 V. D. C. |
| Type: | DC generator driven by AC motor | DC generator driven by AC motor | DC generator driven by AC motor | DC generator driven by AC motor |

ONTARIO
UNIVERSITY

Government
Publication

| | Units 1 & 2 | Units 3 & 4 | Units 5 & 6 | Units 7 & 8 |
|---|--|-----------------------------------|-----------------------------------|-----------------------------------|
| Boiler Feed Pumps | | | | |
| Number of 50% pumps in use: | 2 (plus one spare) electric motor driven | 2 electric motor driven | 2 electric motor driven | 2 electric motor driven |
| Discharge Pressure (psig) | 2,671 | 2,578 | 2,671 | 2,793 |
| Drive Motors (HP electric) | 4,500 | 4,350 | 4,350 | 4,500/5,300 |
| Control | Variable speed hydraulic coupling | Variable speed hydraulic coupling | Variable speed hydraulic coupling | Variable speed hydraulic coupling |
| Number of 10% pumps in use | 0 | 1 electric motor driven | 1 electric motor driven | 1 electric motor driven |
| Discharge Pressure (psig) | - | 2,578 | 2,671 | 2,671 |
| Drive Motors (HP electric) | - | 1,250 | 1,250 | 1,250 |
| Control | - | on-off only non-controlled | on-off only non-controlled | on-off only non-controlled |
| Extraction Heaters | | | | |
| Low Pressure Heaters | 4 per unit | 4 per unit | 4 per unit | 4 per unit |
| High Pressure Heaters | 2 per unit | 2 per unit | 2 per unit | 2 per unit |
| Deaerator | 1 per unit | 1 per unit | 1 per unit | 1 per unit |
| Condensers | | | | |
| Number and type per unit | one twin shell, single pass | one twin shell, single pass | one twin shell, single pass | one twin shell single pass |
| Condenser Surface (sq. feet) | 125,000 | 90,000 | 90,000 | 90,000 |
| Circulating Water Through Condenser (lgpm) | 156,700 | 112,500 | 112,500 | 114,100 |
| Steam Condensed (lbs. per hour) | 1,291,000 | 1,275,730 | 1,275,000 | 1,275,000 |
| Condensate Pumps per Condenser | 3, 50% | 3, 50% | 3, 50% | 3, 50% |
| Capacity Per Pump (lgpm) | 1,430 | 1,460 | 1,460 | 1,460 |
| Rating Per Pump (BHP) | 300 | 350 | 350 | 350 |
| Electrical Service | | | | |
| Main Transformers | one at 340,000 kVA per unit | same as Units 1 & 2 | same as Units 1 & 2 | same as Units 1 & 2 |
| Station Service Transformers (per unit) | 2 at 12,500 kVA | 1 at 25,000 kVA | 1 at 25,000 kVA | 1 at 25,000 kVA |
| Reserve Station Service Transformers | 1 at 25,000 kVA for 2 units | 1 at 25,000 kVA for 2 units | 1 at 25,000 kVA for 2 units | 1 at 25,000 kVA for 2 units |
| Voltage for motors 200 HP and above | 4,000 | 4,000 | 4,000 | 4,000 |
| Voltage for motors below 200 HP including fractional | 550 | 550 | 550 | 550 |
| Coal Handling: | | | | |
| | Common System for whole station. Coal received from self-unloading lakers | | | |
| Capacity of unloading conveyors: | One at 3,000 tons per hour One two-speed at 1,000 or 2,000 tons per hour Combined maximum 5,000 tons per hour | | | |
| Storage Pile | 2,500,000 tons | | | |
| Stockpile Reclaim: | Accomplished by 5 grade level hoppers and 2 runover hoppers | | | |
| Dust and Ash Collection: | | | | |
| Bottom Ash Collected Daily: (wet tons per unit) | 37.5 | 40.8 | 39 | 39 |
| Capacity of Bottom Ash Conveyor Systems: (dry tons of ash per hour) | 40 | 60 | 60 | 60 |
| Capacity of Dewatering Bins: | 1 common 250 dry ton | 2 alternating 250 dry ton | 1 common 250 dry ton | 1 common 250 dry ton |
| Fly Ash Handled: | Dry to silo | Dry to silo | Dry to silo | Dry to silo |
| Fly Ash Conveyed: (Tons/hour/unit) (at 100% Load) | 8.6 | 10.1 | 9.8 | 9.8 |
| Capacity of Silos | one 2,000 ton silo for 2 units | one 2,000 ton silo for 2 units | one 2,000 ton silo for 2 units | One 2,000 ton silo for 2 units |
| Fly Ash Collected (tons/unit/day) | 207 | 242 | 235 | 235 |
| Stacks: | | | | |
| | One stack for 2 units - total of four stacks. Each stack 493 feet above base. Constructed of reinforced concrete with self-supporting brick lining. | | | |